

# Annual Drinking Water Quality Report

## Helmetta Water Department

**For the Year 2024, Results from the Year 2023**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. The Borough of Helmetta bulk purchases all of its water from the East Brunswick Water Utility, who in turn receives its water from the Middlesex Water Company. Middlesex Water is a combination of well and surface water which is explained in further detail in the Middlesex Water Company's Source Water Assessment which is included in this report. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at <https://www.nj.gov/dep/watersupply/swap/index.html> or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding this Source Water Assessment.

**If you are a landlord, you must distribute this Drinking Water Quality Report to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section #3 of NJ P.L. 2021, c.82 (C.58:12A-12.4 et seq.).**

The Helmetta Borough Water Department, the East Brunswick Water Utility and the Middlesex Water Company routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of that monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2023. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

| Helmetta Water Department Test Results – PWS ID# NJ1206001               |               |  |                      |             |        |  |
|--|---------------|--|----------------------|-------------|--------|--|
| Contaminant  | Violation Y/N | Level Detected                               | Units of Measurement | MC LG       | MCL    | Likely Source of Contamination   |
| <b>Inorganic Contaminants:</b>   |               |  |                      |             |        |  |
| Copper<br>Test results Yr. 2021<br>Result at 90 <sup>th</sup> Percentile | N             | 0.19<br>No samples exceeded the action level | ppm                  | 1.3         | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead<br>Test results Yr. 2021<br>Result at 90 <sup>th</sup> Percentile   | N             | ND<br>No samples exceeded the action level   | ppb                  | 0           | AL=15  | Corrosion of household plumbing systems, erosion of natural deposits                                   |
| <b>Disinfection Byproducts:</b>  |               |  |                      |             |        |  |
| TTHMs<br>Total trihalomethanes<br>Test results Yr. 2023                  | N             | Range = 34-82<br>Highest LRAA = 59           | ppb                  | N/A         | 80     | By-product of drinking water disinfection  |
| HAA5s<br>Total Halocetic Acids<br>Test results Yr. 2023                  | N             | Range = 8-40<br>Highest LRAA = 27            | ppb                  | N/A         | 60     | By-product of drinking water disinfection  |
| <b>Regulated Disinfectants</b>   |               | <b>Level Detected</b>                        |                      | <b>MRDL</b> |        | <b>MRDLG</b>   |
| Chlorine<br>Test results Yr. 2022  |               | Range = .34-98 ppm<br>Average = 0.57 ppm     |                      | 4.0 ppm     |        | 4.0 ppm  |

**Chlorine:** Water additive used to control microbes.

HAA5 and TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If you have any questions about this report or concerning your water utility, please contact Paul Reed at 732-521-4946, Ext: 110. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Borough Council meetings at Borough Hall, 51 Main Street, Helmetta, NJ 08828. Meetings are held on the third Wednesday of each month at 7:00 p.m.

| Middlesex Water Company Test Results – PWS ID# NJ1225001       |               |  |                      |       |                                |   |
|--|---------------|--|----------------------|-------|--------------------------------|---|
| Contaminant  | Violation Y/N | Level Detected                                       | Units of Measurement | MC LG | MCL                            | Likely Source of Contamination  |
| <b>Inorganic Contaminants:</b>                                 |               |  |                      |       |                                |   |
| Fluoride<br>Test results Yr. 2023                              | N             | .07  | ppm                  | 4     | 4                              | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Nickel<br>Test results Yr. 2023                                | N             | 1.5  | ppb                  | N/A   | N/A                            | Erosion of natural deposits   |
| Nitrate (as Nitrogen)<br>Test results Yr. 2023                 | N             | 1.1  | ppm                  | 10    | 10                             | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits                               |
| <b>Microbiological Contaminants:</b>                           |               |  |                      |       |                                |   |
| Turbidity<br>Test results Yr. 2023                             | N             | Highest detect = 0.6<br>95% of samples < 0.3         |                      | N/A   | TT<br>95% of samples < 0.3 NTU | Soil runoff, naturally present in the environment.  |
| <b>Disinfection Byproducts:</b>                                |               |  |                      |       |                                |   |
| Bromate<br>Test results Yr. 2023                               | N             | Range = ND – 3<br>Highest average = 3                | ppb                  | 0     | 10                             | By-product of drinking water disinfection   |
| <b>PFAS Per- and Polyfluoroalkyl Substances:</b>               |               |  |                      |       |                                |   |
| PFOA<br>Perfluorooctane Acid<br>Test results Yr. 2023          | N             | Range = 4-9<br>Highest detect = 9<br>Highest RAA = 6 | ppt                  | N/A   | 14                             | Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.                   |
| PFOS<br>Perfluorooctane Sulfonic Acid<br>Test results Yr. 2023 | N             | Range = 3-5<br>Highest detect = 5<br>Highest RAA = 4 | ppt                  | N/A   | 13                             | Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.                   |

**Unregulated Contaminant Monitoring Rule (UCMR)**

The Middlesex Water Company participated in the UCMR in 2023. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. Their results are available upon request.

| Contaminant                      | Level Detected  | Units of Measurement | Likely source   |
|----------------------------------|-----------------|----------------------|---|
| Perchlorate                      | Range = .1 - .2 | ppt                  | Discharge from industrial chemical factories  |
| Perfluorobutane Acid (PFBS)      | Range ND - 2    | ppt                  | Man –made chemical used in the manufacture of fluoropolymers.   |
| Perfluoroheptanoic Acid (PFHepA) | Range = ND - 2  | ppt                  | Man –made chemical used in the manufacture of fluoropolymers.   |
| Perfluorohexanoic Acid (PFHxA)   | Range = 2 - 3   | ppt                  | Man –made chemical used in the manufacture of fluoropolymers.   |
| Chlorate                         | Range = 37 - 94 | ppb                  | Agricultural defoliant of desiccant; disinfection byproduct; used in the production of chloride dioxide   |
| Chromium (VI)                    | Range = .1 - .4 | ppb                  | Naturally-occurring element; used in the making of steel and other alloys; chromium -3 or -6 are used for chrome plating, dyes and pigments, leather tanning, and other wood preservation |
|                                  |                 |                      |   |
|                                  |                 |                      |   |

**What are PFOA and PFOS?**

Perfluorooctanoic acid (PFOA) and perfluorooctane sulfonate (PFOS) are per- and polyfluoroalkyl substances (PFAS), previously referred to as perfluorinated compounds, or PFCs, that are man-made and used in industrial and commercial applications. PFOA was used as a processing aid in the manufacture of fluoropolymers used in non-stick cookware and other products, as well as other commercial and industrial uses based on its resistance to harsh chemicals and high temperatures. PFOS is used in metal plating and finishing as well as in various commercial products. PFOS was previously used as a major ingredient in aqueous film forming foams for firefighting and training, and PFOA and PFOS are found in consumer products such as stain resistant coatings for upholstery and carpets, water resistant outdoor clothing, and grease proof food packaging. Although the use of PFOA and PFOS has decreased substantially, contamination is expected to continue indefinitely because these substances are extremely persistent in the environment and are soluble and mobile in water. More information can be found at:

[https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs\\_PFOA-PFOS-websites-OLA%204-24-19SDM-\(003\).pdf](https://www.state.nj.us/dep/wms/bears/docs/2019-4-15-FAQs_PFOA-PFOS-websites-OLA%204-24-19SDM-(003).pdf)

| East Brunswick Water Utility Test Results – PWS ID# NJ1204001            |               |  |                      |             |      |  |
|--|---------------|--|----------------------|-------------|------|--|
| Contaminant  | Violation Y/N | Level Detected                               | Units of Measurement | MC LG       | MCL  | Likely Source of Contamination                                       |
| <b>Inorganic Contaminants:</b>   |               |  |                      |             |      |  |
| Copper<br>Test results Yr. 2023<br>Result at 90 <sup>th</sup> Percentile | N             | .2<br>No samples exceeded the action level   | ppm                  | 1.3         | AL=0 | Corrosion of household plumbing systems; erosion of natural deposits |
| Lead<br>Test results Yr. 2022<br>Result at 90 <sup>th</sup> Percentile   | N             | 0.00<br>No samples exceeded the action level | ppb                  | 0           | AL=0 | Corrosion of household plumbing systems, erosion of natural deposits |
| <b>Disinfection Byproducts:</b>  |               |  |                      |             |      |  |
| TTHMs<br>Total trihalomethanes<br>Test results Yr. 2023                  | N             | Range = 19.8 -78.2<br>Highest LRAA = 53      | ppb                  | N/A         | 80   | By-product of drinking water disinfection                            |
| HAA5s<br>Total Halocetic Acids<br>Test results Yr. 2023                  | N             | Range = 11.3 - 45<br>Highest LRAA = 30       | ppb                  | N/A         | 60   | By-product of drinking water disinfection                            |
| <b>Regulated Disinfectants</b>   |               | <b>Level Detected</b>                        |                      | <b>MRDL</b> |      | <b>MRDLG</b>   |
| Chlorine<br>Test results Yr. 2023  |               | Range = 0.09– 2.07ppm<br>Average = 1.03 ppm  |                      | 4.0 ppm     |      | 4.0 ppm  |

**Chlorine:** Water additive used to control microbes.

HAA5 and TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

**Unregulated Contaminant Monitoring Rule (UCMR)**

The East Brunswick Water Department participated in the UCMR in 2023. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. Their results are available upon request.

| Contaminant                               | Level Detected   | Units of Measurement | Likely source   |
|---|------------------|----------------------|---|
| Perfluorooctane Sulfonic Acid (PFOS) 2023 | Range = ND – 4.3 | ppt                  | Man –made chemical used in the manufacture of fluoropolymers. |
| Perfluorooctanoic Acid (PFOA)2023         | Range ND – 7.7   | ppt                  | Man –made chemical used in the manufacture of fluoropolymers. |
| Perfluoropentanoic Acid (PFPeA) 2023      | Range = ND - 3   | ppt                  | Man –made chemical used in the manufacture of fluoropolymers. |
|   |                  |                      |   |

**Sources of Lead in Drinking Water**

The Helmetta Water Department and its suppliers are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Although most lead exposure occurs from inhaling dust or from contaminated soil, or when children eat paint chips, the U.S. Environmental Protection Agency (USEPA) estimates that 10 to 20 percent of human exposure to lead may come from lead in drinking water. Infants who consume mostly mixed formula can receive 40 percent to 60 percent of their exposure to lead from drinking water. Lead is rarely found in the source of your drinking water but enters tap water through corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing materials. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, service lines made of or lined with lead. New brass faucets, fittings, and valves, including those advertised as “lead-free”, may still contain a small percentage of lead, and contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 0.25 percent lead to be labeled as “lead free”. However, prior to January 4, 2014, “lead free” allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Visit the NSF website at [www.nsf.org](http://www.nsf.org) to learn more about lead-containing plumbing fixtures. Consumers should be aware of this when choosing fixtures and take appropriate precautions. When water stands in lead service lines, lead pipes, or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

**Steps You Can Take to Reduce Exposure to Lead in Drinking Water**

For a full list of steps visit: <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>

**Run the cold water to flush out lead.** Let the water run from the tap before using it for drinking or cooking any time the water in the faucet has gone unused for more than six hours. The longer the water resides in plumbing the more lead it may contain. Flushing the tap means running the cold-water faucet. Let the water run from the cold-water tap based on the length of the lead service line and the plumbing configuration in your home. In other words, the larger the home or building and the greater the distance to the water main (in the street), the more water it will take to flush properly. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

Use cold, flushed water for cooking and preparing baby formula. Because lead from lead-containing plumbing materials and pipes can dissolve into hot water more easily than cold water, never drink, cook, or prepare beverages including baby formula using hot water from the tap. If you have not had your water sampled or if you know, it is recommended that bottled or filtered water be used for drinking and preparing baby formula. If you need hot water, draw water from the cold tap and then heat it.

**Do not boil water to remove lead.** Boiling water will not reduce lead; however, it is still safe to wash dishes and do laundry. Lead will not soak into dishware or most clothes.

**Use alternative sources or treatment of water.** You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or [www.nsf.org](http://www.nsf.org) for information on performance standards for water filters.

**Determine if you have interior lead plumbing or solder.** If your home/building was constructed prior to 1987, it is important to determine if interior lead solder or lead pipes are present. You can check yourself, hire a licensed plumber, or check with your landlord.

**Replace plumbing fixtures and service lines containing lead.** Replace brass faucets, fittings, and valves that do not meet the current definition of "lead free" from 2014 (as explained above). Visit the NSF website at [www.nsf.org](http://www.nsf.org) to learn more about lead-containing plumbing fixtures.

**Remove and clean aerators/screens on plumbing fixtures.** Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

**Test your water for lead.** Please call 732-521-0386 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

**Get your child tested.** Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. New Jersey law requires that children be tested for lead in their blood at both 1 and 2 years of age and before they are 6 years old if they have never been tested before or if they have been exposed to a known source of lead.

**Have an electrician check your wiring.** If grounding wires from the electrical system are attached to your pipes, corrosion may be greater. Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.

**Water softeners and reverse osmosis units** will remove lead from water but can also make the water more corrosive to lead solder and plumbing by removing certain minerals; therefore, the installation of these treatment units at the point of entry into homes with lead plumbing should only be done under supervision of a qualified water treatment professional.

### **Health Effects of Lead**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. You can find out more about how to get your child tested and how to pay for it at <https://www.state.nj.us/health/childhoodlead/testing.shtml>.

**In July 2021, P.L.2021, Ch.183 (Law) was enacted, requiring all community water systems to replace lead service lines in their service area within 10 years. Under the law, The Helmetta Water Department is required to notify customers, non-paying consumers, and any off-site owner of a property (e.g., landlord) when it is known they are served by a lead service line\*. Our service line inventory is available upon request.**

### **DEFINITIONS**

In the "Test Results" tables you may find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** or nanogram per liter - one part per trillion corresponds to one minute in 20,000 years, or a single penny in \$100,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Action Level** - the concentration of a contaminant, which if exceeded, triggers treatment or other requirements, which a water system must follow.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Secondary Contaminant**- Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Turbidity** - A measure of the particulate matter or "cloudiness" of the water. High turbidity can hinder the effectiveness of disinfectants.

**Recommended Upper Limit (RUL)** - Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RULs are recommendations, not mandates.

**Running Annual Average** - RAA calculation is based on four completed quarters of monitoring results.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

### **Cryptosporidium**

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Cryptosporidium is usually removed through the filtration process and inactivated by other treatment processes such as chlorination and / or ozonation. In order to check for the presence of Cryptosporidium, the USEPA issued the Long-Term Enhanced Surface Water Treatment Rule in January 2006. Our sample results did not show any presence of Cryptosporidium. We believe it is important for you to know that cryptosporidium may cause serious illness in immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. These people should seek advice from their health care providers.

**Middlesex Water Company- PWSID # NJ1225001**

Middlesex Water Company is a public community water system consisting of 31 wells, 1 surface water intake, 1 purchased ground water source, and 1 purchased surface water source.

This system’s source water comes from the following aquifers and/or surface water bodies: glacial sand and gravel, Brunswick Aquifer System, Delaware & Raritan Canal

This system purchases water from the following water systems: New Jersey Water Supply Authority, New Jersey American Water – Raritan System

**Susceptibility Ratings for Middlesex Water Company Sources**

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system’s source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes’ susceptibility to radionuclides was not determined and they all received a low rating.

**If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

| Sources                   | Pathogens |    |   | Nutrients |    |   | Pesticides |   |    | Volatile Organic Compounds |   |   | Inorganics |    |   | Radionuclides |    |   | Radon |   |   | Disinfection Byproduct Precursors |    |   |
|---------------------------|-----------|----|---|-----------|----|---|------------|---|----|----------------------------|---|---|------------|----|---|---------------|----|---|-------|---|---|-----------------------------------|----|---|
|                           | H         | M  | L | H         | M  | L | H          | M | L  | H                          | M | L | H          | M  | L | H             | M  | L | H     | M | L | H                                 | M  | L |
| Wells - 31                |           | 29 | 2 | 10        | 21 |   |            | 4 | 27 | 31                         |   |   | 14         | 17 |   | 3             | 28 |   | 31    |   |   | 14                                | 17 |   |
| Surface water intakes - 1 | 1         |    |   | 1         |    |   |            | 1 |    |                            | 1 |   | 1          |    |   |               |    | 1 |       |   | 1 | 1                                 |    |   |

- Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.
- Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.
- Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.
- Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.
- Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.
- Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.
- Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.
- Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

**We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children’s future. Please call our office if you have questions.**